

**Office of the Executive Engineer
Public Health Division, Kaimur (Bhabhua)
Division Laboratory -Bhabhua**

Issue Date -15-05-2025

Zone - Patna

Division Name - Bhabhua

Water Test Report

Water Sample Details						(Values in mg/L , Except pH otherwise mentioned)													
Sl. No.	Block	Panchayat / Town	Village / Locality	Name of Habitation / Ward No.	Location/ Source of sample	pH	Turb.	EC	TDS	T. Hard	Ca	Mg	Cl	T. Alka	Fe	NO3	SO4	F	Total coli.
1	Ramghad	Ramghad	Bandipur	Ground Water	Sarswati Shishu Mandir Bandipur	7.00	1.00	945.00	616.00	220.00	32.16	30.20	72.00	244.00	0.10	BDL	10.00	0.21	NT
Desirable Limit						6.5-8.5	1.00	—	500	200	75	30	250	200	1	45	200	1	
Drinking Water Specification (Second revision) IS 10500 / 2012 Permissible limit in absence of alternate source.						NR	5.0 NTU	—	2000	600	200	100	1000	600	NR	NR	400	1.5	

* Note :- Water Sample collected by -Sarswati Shishu Mandir Bandipur, Ramghad

Ashok Kumar
15/05/2025
Chemist
P.H. Division, Bhabhua

Sanyal
13/5/24
Assistant Engineer
P.H.Division, Bhabhua

[Signature]
Executive Engineer
P.H. Division, Bhabhua